

Clinical Laboratory of San Bernardino, Inc.



Santa Ynez Valley Presbyterian Preschool
1825 Alamo Pintado Rd.
Solvang CA, 93463

Project: Lead Sampling
Sub Project:
Project Manager: Rhonda Graff

Work Order: 22G0057
Received: 07/01/22 14:12
Reported: 07/11/22

421700345 F **22G0057-01 (Water)** **Sample Date:** 06/30/22 7:27 **Sampler:** David Bazzell

Analyte	Method	Result	Units	Rep. Limit	MDL	MCL	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	-------	------------	-----	-----	----------	----------	-------	-----------

Metals

Lead (Low Level) EPA 200.8 **5.7** ug/L 1.0 0.10 07/06/22 07/07/22 2228068

421700345 K **22G0057-02 (Water)** **Sample Date:** 06/30/22 7:30 **Sampler:** David Bazzell

Analyte	Method	Result	Units	Rep. Limit	MDL	MCL	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	-------	------------	-----	-----	----------	----------	-------	-----------

Metals

Lead (Low Level) EPA 200.8 **5.8** ug/L 1.0 0.10 07/06/22 07/07/22 2228068

421700345 N **22G0057-03 (Water)** **Sample Date:** 06/30/22 7:32 **Sampler:** David Bazzell

Analyte	Method	Result	Units	Rep. Limit	MDL	MCL	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	-------	------------	-----	-----	----------	----------	-------	-----------

Metals

Lead (Low Level) EPA 200.8 **7.0** ug/L 1.0 0.10 07/06/22 07/07/22 2228068

421700345 P **22G0057-04 (Water)** **Sample Date:** 06/30/22 7:34 **Sampler:** David Bazzell

Analyte	Method	Result	Units	Rep. Limit	MDL	MCL	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	-------	------------	-----	-----	----------	----------	-------	-----------

Metals

Lead (Low Level) EPA 200.8 **7.9** ug/L 1.0 0.10 07/06/22 07/07/22 2228068

421700345 Q **22G0057-05 (Water)** **Sample Date:** 06/30/22 7:37 **Sampler:** David Bazzell

Analyte	Method	Result	Units	Rep. Limit	MDL	MCL	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	-------	------------	-----	-----	----------	----------	-------	-----------

Metals

Lead (Low Level) EPA 200.8 **5.3** ug/L 1.0 0.10 07/06/22 07/07/22 2228068

U Analyte included in the analysis, but not detected

ND Analyte NOT DETECTED at or above the MDL; Method Detection Limit


Nate Fresquez
Project Manager

0/0/5 pd-ck# 5879

Clinical Lab of San Bernardino, Inc.

21881 Barton Road Grand Terrace CA 92313 909 825-7693 / 516-A N 8th St. Lompoc CA 93436 805 737-7300

WO 2160051

Client		Destination Laboratory		Analysis Requested	
Santa Ynez Valley Presbyterian Preschool Address: 1825 Alamo Pintado Rd. Solvang, CA 93463 Client Contact: Rhonda Graef Phone No.: (805) 688-4470 FAX No.: System No.:		<input type="checkbox"/> Clinical Grand Terrace / ELAP 1088 <input checked="" type="checkbox"/> Clinical Lompoc / ELAP 1678 <input type="checkbox"/> Other:		LEAD 200.8 RL=1 PPB	
Project: LEAD SAMPLING IN CHILD CARE CENTERS		Sample Type		Total Containers	
Sampled By: David Bazzell		Matrix		Unpreserved	
Comments: EMAIL RESULTS TO: DIRECTOR@SVPD.CA.GOV		Container ID		ZnC4H6O4	
DOB@COMA.COM & SURCS (DRINKING WATER)		Sample Identification		Na2SO3	
Date	Time				
6/30/12	0727	421700345	F		10
6/30/12	0730	421700345	K		10
6/30/12	0732	421700345	N		10
6/30/12	0734	421700345	P		10
6/30/12	0737	421700345	Q		10
STAGNANT AND STIMULATED 100% H2O2 10/20/12					
Matrix: DW - Drinking Water GW - Ground Water SW - Surface Water W - Water WW - Wastewater SWR - Stormwater Runoff S - Sludge O - Other					
Use for Bacteria Samples / Sample Type: 1-Routine 2-Repeat 3-Replacement 4-Special D-Distribution W-Well TAT: (10) Ten Day (5) Five Day Rush (2) Two Day Rush					
Relinquished By (Sign)		Print Name / Company		Received By (Sign)	
 David Bazzell Santa Ynez Valley Presbyterian Preschool		6/30/12 / 1432 06/30/12 / 1435 07/12/12 07/12/12		Jen Kinata / CLS57 [Signature] Bridget Dand / CLS5	
(Lab Use Only) Lompoc Lab Receipt Temp.: 16°C					
Shipped Via: <input type="checkbox"/> Fed Ex <input type="checkbox"/> Golden State Overnight <input type="checkbox"/> UPS <input type="checkbox"/> OnTrac <input type="checkbox"/> USPS <input type="checkbox"/> Other					
Condition: <input type="checkbox"/> On Wet Ice <input type="checkbox"/> On Blu Ice <input type="checkbox"/> Intact <input type="checkbox"/> Custody Seals <input type="checkbox"/> Samples / COC Checked By:					
Receipt Comments:					
Work Order Logged By: <u>1906</u> Clinical Lab Receipt Temp.: <u>19.6</u>					